



TECHNICKÁ INŠPEKCIA, a.s.



SLOVENSKÁ REPUBLIKA

AUTHORIZATION

Authorization registration no.:

131/1/2012 – PZ – O (OU, R, M) – Ae,f,g,h, Be,f,g,h1

issued according to the § 14 part 1, letter. a) and § 15 para. 4 of the Act no. 124/2006 Coll. On Safety and Health Protection at Work following the Expert opinion no.: 2369/3/2012 from expert competence verification by Technická inšpekcia, a.s.

Name and address: **SLOVING, spol. s r.o.**

Vrakunská 29

825 63 Bratislava

ID no: **17 321 069**

Activities:

- O Repairs of restricted gas technical equipment within the range:**
- OU Repair and Maintenance**
 - R Reconstruction**
 - M Mounting to functional entity at place of intended service**

Scope:

Gas technical equipment of group A:

- e increasing the pressure of gas with an output gas pressure exceeding 0.4 MPa**
- f reducing the pressure of gas with an input gas pressure exceeding 0.4 MPa**
- g the distribution of gas with a gas pressure above 0.4 MPa**
- h gas consumption via combustion with an output of a unitary device or total output of individual devices constituting a functional unit exceeding 0.5 MW including devices for producing protective atmospheres during heat treatment**

Gas technical equipment of group B:

- e increasing the pressure of gas with an output gas pressure of up to and including 0.4 MPa**
- f reducing the pressure of gas with an input gas pressure of up to and including 0.4 MPa with an output of greater than 25 Nm³/h with the exception of devices included in Category B Letter g)**
- g gas distribution including regulation equipment for gas connections with a gas device take-off performance of up to and including 25 Nm³/h with an output gas pressure of up to and including 0.4 MPa, with the exception of acetylene hydrate**
- h1 gas consumption via combustion with an output from 5 kW to 0.5 MW including devices for producing protective atmospheres during heat treatment and appliances requiring a connected line for combustion gas exhaust**

Authorization holder during activity according to the authorization shall keep to the terms given in the Expert opinion no.: 2369/1/2012 from 21st June 2012.

Bratislava, 21st June 2012




Ing. Ľudovít Zeman
Director of regional office Bratislava

200871

OPRPZ6-271